


IMPORTANT LIFE SAFETY NOTE
 4-1/2" MINIMUM FACE OF SLAB (AS SHOWN)
 REQUIRED FOR OPTIONAL FIRE RATING TO
 BE AVAILABLE.
 ARCHITECT / CONTRACTOR MUST VERIFY
 PRIOR TO FABRICATION.

IMPORTANT LIFE SAFETY PRODUCT NOTE
 PF-2018F-SC-9-4.5 (OPTIONAL)
 TO ACHIEVE RATING, 2-HOUR FIRE BARRIER
 MUST BE INSTALLED IN 2-HOUR RATED SLAB,
 MINIMUM 4-1/2" JT. FACE BARRIERS MUST BE
 INSTALLED IN STRICT ACCORDANCE WITH
 TYPICAL FLOOR FIRE BARRIER INSTALLATION
 INSTRUCTIONS PROVIDED IN THIS SUBMITTAL.
 *CONTACT FACTORY FOR OTHER STYLES OF FIRE BARRIER

Model	Nominal "JT"	Joint Opening "JT"				Total Movement	Mat. Code
		Seismic Min.	Thermal Min.	Thermal Max.	Seismic Max.		
RXH-9-4.5	9"	0.25"	6.75"	11.25"	13.375"	13.125"	MR1013
RXH-9-4.5 w/ PF-2018F-SC-9-4.5	9"	3.5"	6.75"	11.25"	13.375"	9.875"	MR1013

Representative: _____ Customer: _____ Project: _____ Location: _____ Project Number: _____



MM

50 MM WAY
 PENDERGRASS, GA. 30567
 PHONE: 706-824-7500
 800-241-3460
 FAX: 706-824-7501

www.mmssystemscorp.com

For Spec-Data, Installation Guides, or movement requirements, contact MMISC

RIGHTS OF DESIGN

All rights of design, detail, engineering and/or invention contained herein are the property of MM Systems Corporation and hereby reserved and are not to be reproduced or provided to any other party. MM Systems Corporation reserves the right to amend or withdraw any information contained herein without notice and will not be liable for any inaccuracy or ambiguity of said information.

Model:

RXH-9-4.5

Drawn by: LMP

Scale: NTS

SHT. OF

Issue Date: 06-08-09

Drawing Number:

MR1013