


IMPORTANT LIFE SAFETY NOTE
 4-1/2" MINIMUM FACE OF SLAB(S) SHOWN
 REQUIRED FOR OPTIONAL FIRE RATING TO
 BE AVAILABLE IN ACCORDANCE TO IBC
 TABLE 721.2.2.1 "MINIMUM SLAB THICKNESS"
 ARCHITECT / CONTRACTOR MUST VERIFY
 PRIOR TO FABRICATION.

IMPORTANT LIFE SAFETY PROVISION NOTE
 PF-2248CF-SC-24-24 (OPTIONAL)
 TO ACHIEVE RATING, 2-HOUR FIRE BARRIER
 MUST BE INSTALLED IN 2-HOUR RATED SLAB.
 MINIMUM 4-1/2" JT. FACE BARRIERS MUST BE
 INSTALLED IN STRICT ACCORDANCE WITH
 TYPICAL FLOOR FIRE BARRIER INSTALLATION
 INSTRUCTIONS PROVIDED IN THIS SUBMITTAL.
 *CONTACT FACTORY FOR OTHER STYLES OF FIRE BARRIER.

Model	Nominal "JT"	Joint Opening "JT"				Total Movement	Mat. Code
		Seismic Min.	Thermal Min.	Thermal Max.	Seismic Max.		
LASB-NB-24-24	24"	2.5"	23.625"	24.375"	48"	45.5"	
LASB-NB-24-24 w/ PF-2248CF-SC-24-24	24"	5"	23.625"	24.375"	48"	43"	

Representative:	Customer:	Project:	Location:	Project Number:
 MM SYSTEMS 50 MM WAY PENDERGRASS, GA. 30567 PHONE: 706-824-7500 800-241-3460 FAX: 706-824-7501 www.mmsystemscorp.com		RIGHTS OF DESIGN All rights of design, detail, engineering and/or invention contained herein are the property of MM Systems Corporation and hereby reserved and are not to be reproduced or provided to any other party. MM Systems Corporation reserves the right to amend or withdraw any information contained herein without notice and will not be liable for any inaccuracy or ambiguity of said information.		
		LASB-NB-24-24		
		Model:	Drawn by:	Scale:
	LMP	NTS		
SHT. . OF .		Issue Date:		
		07-18-12		

For Spec-Data, Installation Guides, or movement requirements, contact MMSC