


Model	Nom	Nominal Nominal		Thermal Movement (JO₁)				Seismic Movement (JOs)				Total (JO∆)		
Number	(10 _V)		(SL _N)		Minimum		Maximum		Minimum		Maximum		Movement	
SSM-C-250	1.50	38	3.00	76	0.75	19	2.50	64	0.75	19	3.25	83	2.50	64
SSM-C-350	2.25	57	3.50	89	1.00	25	3.50	89	1.00	25	4.25	108	3.25	83
SSM-C-450	3.00	76	4.25	108	1.50	38	4.50	114	1.50	38	5.50	140	4.00	102
SSM-C-550	4.00	102	5.25	133	1.50	38	5.50	140	1.50	38	6.50	165	5.00	127

Dimension shown in inches (bold) and millimeters. JO = Joint Opening. SL = Sight Line. Color Options for rubber seals are Black or Special Order Gray.



SSM Series Adjustable Height Expansion Joint

(Slab-to-Wall)

2-HOUR RATED SLAB WITH MINIMUM 4.50" JOINT FACE, BARRIERS MUST BE INSTALLED IN STRICT ACCORDANCE WITH MM SYSTEMS FIRE BARRIER INSTALLATION INSTRUCTIONS AND IN ACCORDANCE TO IBC TABLE 721.2.2.1 "MINIMUM SLAB THICKNESS" (CONTACT FACTORY FOR OTHER STYLES OF FIRE BARRIER)



50 MM WAY PENDERGRASS, GA. 30567 706-824-7500 PHONE 866-506-6929 TOLL FREE 706-824-7501 FAX

www.mm-usa.com

For Spec-Data, Install Guides and other data visit www.mm-usa.com.

RIGHTS OF DESIGN

All rights of design, detail, engineering and/or invention contained herein are the property of MM Systems Corporation and herby reserved and are not to be reproduced or provided to any other party. MM Systems Corporation reserves the right to amend or withdraw any information contained herein without notice and will not be liable for any inaccuracy or ambiguity of said information.

Split Slab Membrane System Expansion Joint SSM-C Adjustable Height Fire Rated

Drawn by:	Scale:	Drawing Number:
DMW	NTS]
SHT. 1 OF 1	Issue Date: 07-14-2017	41203

41203-07